


PV 216S0F3CXXV000TXPX15PWW**Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

**Standard portfolio for combiner boxes.****Protect and monitor strings in a solar park.**

Weidmüller has developed a full portfolio of standard PV DC combiner boxes for solar parks. These products intend to cover the most common used solutions for such purposes in an efficient and competitive manner. From 6 up to 32 inputs our Generation X offers a full range of products for monitored and non-monitored combiner boxes allowing our customer to benefit from Weidmüller's experience and commitment to quality. Gen X

General ordering data

| | |
|------------|--|
| Version | Photovoltaics, Assembled enclosure, Combiner Box, 1500 V, With fuse holder, Surge protection II, Cable gland, for wall mounting, Switch disconnect, Portrait, Central Inverter |
| Order No. | 8000078118 |
| Type | PV 216S0F3CXXV000TXPX15PWW |
| GTIN (EAN) | 8430243427180 |
| Qty. | 1 pc(s). |

PV 216S0F3CXXV000TXPX15PWW

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

Dimensions and weights

| | | | |
|------------|----------|-----------------|-------------|
| Depth | 300 mm | Depth (inches) | 11.811 inch |
| Height | 747 mm | Height (inches) | 29.409 inch |
| Width | 536 mm | Width (inches) | 21.102 inch |
| Net weight | 25,000 g | | |

Temperatures

| | | | |
|---------------------|-----------------|-----------------------|-----------------|
| Ambient temperature | -20°C to +50 °C | Operating temperature | -20°C to +50 °C |
|---------------------|-----------------|-----------------------|-----------------|

DC electrical properties

| | | | |
|--------------------------|---------------------------------------|--------------------|----------------------|
| Earthing | Directly at the VPU | Rated voltage | 1,500 V |
| Surge protection DC side | 1500 V type II without remote contact | Switching capacity | 400 A (DC21B 1500 V) |

DC inputs

| | | | |
|---------------------------------|------------------------------------|-------------------------|-----------------|
| Cartridge fuse | 10 x 85 mm | | |
| Connection DC input cable (+) | Screw connection | | |
| Connection DC input cable (-) | Screw connection | | |
| Connection type, DC input cable | Cable gland | | |
| DC Input + & - | Wire connection | Type of connection | M16 Cable gland |
| | Cable entry | Number of cable entries | 32 |
| | | Cable diameter, min. | 5 mm |
| | | Cable diameter, max. | 10 mm |
| Functional earth connector | Cable entry | Number of cable entries | 1 |
| | | Cable diameter, min. | 6 mm |
| | | Cable diameter, max. | 12 mm |
| | Wire connection | Type of connection | M20 Cable gland |
| Fuse | 15 A, 16 A, 20 A, 25 A, 30 A, 32 A | | |
| Fuse | Empty fuse holder | | |
| Fuse type | Empty fuse holder | | |
| Fuse-link standard | gPV (EN 60269-6) | | |
| Fused poles of string | +/- | | |
| Number of DC inputs | 16 | | |
| Number of conduit inlets | 35 | | |
| Number of inputs | 16 | | |
| Position of the fuses | positive and negative inputs | | |

DC outputs

| | | | |
|---|-----------------------------|--------------------------|---------------------|
| DC Output + & - | Wire connection | Type of connection | M40 Cable gland |
| | | Wire cross-section, min. | 150 mm ² |
| | | Wire cross-section, max. | 300 mm ² |
| DC output cable connection | M10 bolt and nut connection | | |
| Load circuit breaker with auxiliary contact | No | | |
| Number of DC outputs | 2 | | |

PV 216S0F3CXXV000TXPX15PWW

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

DC string monitoring

| | |
|---------------------|---------------|
| Monitoring function | Non monitored |
|---------------------|---------------|

Housing

| | | | |
|-------------------|------|------------------|---------------|
| Protection degree | IP65 | Type of mounting | Wall mounting |
|-------------------|------|------------------|---------------|

Norms and standards

| | |
|-----------|-------------------------------------|
| Standards | EN 61439-2:2011, IEC 61439-2 ed 3.0 |
|-----------|-------------------------------------|

Guarantee

| | |
|---------------|---------|
| Time interval | 5 years |
|---------------|---------|

Classifications

| | | | |
|-------------|-------------|-------------|-------------|
| ETIM 6.0 | EC002928 | ETIM 7.0 | EC002928 |
| ETIM 8.0 | EC003857 | ETIM 9.0 | EC003857 |
| ECLASS 9.0 | 22-57-92-03 | ECLASS 9.1 | 22-57-02-90 |
| ECLASS 10.0 | 22-57-02-90 | ECLASS 11.0 | 22-57-02-92 |
| ECLASS 12.0 | 22-57-02-92 | ECLASS 13.0 | 22-57-02-92 |
| ECLASS 14.0 | 22-57-02-92 | | |

Environmental Product Compliance

| | |
|--------------------------------------|--------------------------------------|
| RoHS Compliance Status | Compliant with exemption |
| RoHS Exemption (if applicable/known) | 6c |
| REACH SVHC | Lead 7439-92-1 |
| SCIP | 1d28ada4-1634-4382-8635-45f6353a6574 |

Approvals

Approvals



| | |
|------|---------|
| ROHS | Conform |
|------|---------|

Downloads

| | |
|---|---|
| Approval/Certificate/Document of Conformity | EU Declaration of Conformity Combiner Boxes non monitored |
| Engineering Data | CAD data – STEP Electrical Drawing |
| Technical Documentation | Mechanical Drawing |
| User Documentation | User Manual PV DC Combiner Boxes |
| Catalogues | Catalogues in PDF-format |

PV 216S0F3CXXV000TXPX15PWW

Weidmüller Interface GmbH & Co. KG
Klingenbergstraße 26
D-32758 Detmold
Germany

www.weidmueller.com

Drawings



PV 216S0F3CXXV000TXPX15PWW

Weidmüller Interface GmbH & Co. KG
Klingenbergstraße 26
D-32758 Detmold
Germany

www.weidmueller.com

Drawings

Combiner Box Name Description

PV 2 24 S0 FX CXX VX OX TXPX 15 P F ES

PV 1: PV DC L0 Industrial
PV 2: PV DC L1 Industrial
PV 3: PV DC L2 Industrial

Number of inputs (01-36)

S0: Switch-disconnector
S0 → Switch-disconnector (SW)
S1 → Switch-disconnector with remote disconnection (SW RD)
S2 → Molded Case Circuit Breaker (MCCB)
S3 → Molded switch-disconnector (SW M)
S4 → Switch-disconnector with Contactor (SW K)
S5 → No switch-disconnector needed (N/A)

FX: Fuses / Fuseholders position

F0 → Fuses Both Poles
F1 → Only Positive Fuses
F2 → Only Negative Fuses
F3 → Only Fuse Holders
F4 → Only Fuse holder in positive (+)
F5 → Only Fuse holder in negative (-)
FX → No Fuse holders needed (N/A)

CXX: CIL Fuses Type → C 10/15/16/20/25/30/40/50/55/60/63/80 - (Example C20)
NXX: NH Fuses Type → N 40/50/63/80/100/125/160/200/250/315/355/400 - (Example N40)
CXX → N/A, NXX → N/A

VX: SPD Type

V0 → SPD Class II / V1 → SPD Class I+II / V2 → SPD Class I
VX → No SPD needed (N/A)

OX: Output type
O0 → No holder needed (N/A)
O1 → Cable Gland
O2 → M24
O3 → M24
O4 → M24

Country / Whole World

Floating: YES (F) / NO

P: Portrait

L: Landscape

10: 1000V

15: 1500V

TX: Monitoring Device

TX → No monitoring (N/A)
T0 → TC 24V (24V or 1.3kV)
T1 → TC 24V
T2 → TC 24V
T3 → TC 24V
T4 → TC 24V
T5 → TC 24V
T6 → TC 24V
T7 → TC 24V
T8 → TC 24V
T9 → TC 24V
T10 → TC 24V
T11 → TC 24V
T12 → TC 24V
T13 → TC 24V
T14 → TC 24V
T15 → TC 24V
T16 → TC 24V
T17 → TC 24V
T18 → TC 24V
T19 → TC 24V
T20 → TC 24V
T21 → TC 24V
T22 → TC 24V
T23 → TC 24V
T24 → TC 24V
T25 → TC 24V
T26 → TC 24V
T27 → TC 24V
T28 → TC 24V
T29 → TC 24V
T30 → TC 24V
T31 → TC 24V
T32 → TC 24V
T33 → TC 24V
T34 → TC 24V
T35 → TC 24V
T36 → TC 24V
T37 → TC 24V
T38 → TC 24V
T39 → TC 24V
T40 → TC 24V
T41 → TC 24V
T42 → TC 24V
T43 → TC 24V
T44 → TC 24V
T45 → TC 24V
T46 → TC 24V
T47 → TC 24V
T48 → TC 24V
T49 → TC 24V
T50 → TC 24V
T51 → TC 24V
T52 → TC 24V
T53 → TC 24V
T54 → TC 24V
T55 → TC 24V
T56 → TC 24V
T57 → TC 24V
T58 → TC 24V
T59 → TC 24V
T60 → TC 24V
T61 → TC 24V
T62 → TC 24V
T63 → TC 24V
T64 → TC 24V
T65 → TC 24V
T66 → TC 24V
T67 → TC 24V
T68 → TC 24V
T69 → TC 24V
T70 → TC 24V
T71 → TC 24V
T72 → TC 24V
T73 → TC 24V
T74 → TC 24V
T75 → TC 24V
T76 → TC 24V
T77 → TC 24V
T78 → TC 24V
T79 → TC 24V
T80 → TC 24V
T81 → TC 24V
T82 → TC 24V
T83 → TC 24V
T84 → TC 24V
T85 → TC 24V
T86 → TC 24V
T87 → TC 24V
T88 → TC 24V
T89 → TC 24V
T90 → TC 24V
T91 → TC 24V
T92 → TC 24V
T93 → TC 24V
T94 → TC 24V
T95 → TC 24V
T96 → TC 24V
T97 → TC 24V
T98 → TC 24V
T99 → TC 24V

PX: Power Supply for (TX)

PX → No Power Supply Needed (N/A)
P0 → Self-Powered (SEI)
P1 → External Power Supply (PS ACDC)
P2 → Self-Powered (SEI)

