

**ENERGY ANALYSER 550-24****Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

[www.weidmueller.com](http://www.weidmueller.com)**Energy analysers**

More and more non-linear consumers and plant components are finding their way into production facilities. They influence, for example, mains frequency, phase shift and amplitudes of the phases.

This has an influence on the quality of the electrical energy and thus on plant availability.

The energy analysers measure all quality parameters - from the parameters of symmetry to transients - and many more.

After comprehensive testing, optimisation steps can then be initiated to maximise the efficiency and availability of the plants.

**General ordering data**

Order No.	<a href="#">2602580000</a>
Type	ENERGY ANALYSER 550-24
GTIN (EAN)	4050118655841
Qty.	1 pc(s).

## ENERGY ANALYSER 550-24

Weidmüller Interface GmbH &amp; Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

## Technical data

## Dimensions and weights

Depth	81 mm	Depth (inches)	3.189 inch
Height	144 mm	Height (inches)	5.669 inch
Width	144 mm	Width (inches)	5.669 inch
Net weight	1,080 g		

## Temperatures

Storage temperature	-25 °C...70 °C	Operating temperature	-10 °C...55 °C
Humidity	5...95 %, no condensation		

## Measuring current input

Current-measuring channels	4 + 2	Distortion factor THD-I in %	Yes
Harmonics, per order / current	1..63.	Measuring accuracy for current	0.2 %
Rated current	1 / 5 A	Residual current measuring	Yes

## Measuring voltage input

Distortion factor THD-U in %	Yes	Four-wire system	Yes
Harmonics, per order / voltage	1..63.	Measurement range, voltage L-L, AC	720 V
Measurement range, voltage L-N, AC	417 V	Measuring accuracy for voltage	0.1 %
Quadrants	4	Three-wire system	Yes

## Communication

Interface	Protocol	Modbus RTU, Modbus-Gateway, Modbus TCP/IP, Modbus RTU over Ethernet, SNMP, Profibus DP V0, BACnet (optional)
RS485: 9.6 – 921.6 kbps, Profibus DP, Ethernet, Web server/e-mail		

## Inputs/outputs

Number of digital inputs	2	Number of digital outputs	2
Number of pulse outputs	2	Temperature input	Yes

## Measurement data recording

Memory; minimum and maximum values	Yes	Memory size	256 MB
Number of memory values	10,000 k	Update interval register	200 ms
Min. memory recording interval	1 s	Software	ecoExplorer go®
Integrated logic	Yes		

## ENERGY ANALYSER 550-24

Weidmüller Interface GmbH &amp; Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

## Technical data

## Technical data

Protection degree	IP20, IP40	Rated current	1 / 5 A
Version		Standards	DIN EN 61326-1, DIN EN 61000-4-2, DIN EN 61000-4-3, DIN EN 61000-4-4, DIN EN 61000-4-5, DIN EN 61000-4-6, EN 61000-4-11, EN 55011, IEC 61010-1, IEC 61010-2-030, DIN EN 61000-4-8
	Power measurement/dis- play for 1-, 3-phase mains		
Measurement range, voltage L-N, AC	417 V	Measurement range, voltage L-L, AC	720 V
Surge voltage category	600 V CAT III	Voltage supply	48...110 V AC, 24...150 V DC
Three-wire system	Yes	Four-wire system	Yes
Quadrants	4	Sampling frequency 50/60 Hz	20 kHz
Continuous measurements	Yes	Measurement result per second	5 ms
Effective value from the period (50/60 Hz)	10 / 12	Residual current measuring	Yes
Current-measuring channels	4 + 2	Measuring accuracy for voltage	0.1 %
Measuring accuracy for current	0.2 %	Measurement accuracy for active energy (kWh, .../5 A)	Class 0.2S
Operating-hours counter	Yes	Weekly time switch	Yes
Clock	Yes	Bimetal function	Yes

## Voltage quality measurement

Harmonics, per order / voltage	1-63.	Harmonics, per order / current	1-63.
Distortion factor THD-U in %	Yes	Distortion factor THD-I in %	Yes
Unbalanced	Yes	Positive, negative and zero system	Yes
Brief interruptions	Yes	Sequence-of-events recorder function	Yes


## Insulation coordination

Surge voltage category	600 V CAT III
------------------------	---------------

## Classifications

ETIM 6.0	EC002301	ETIM 7.0	EC002301
ETIM 8.0	EC002301	ETIM 9.0	EC002301
ECLASS 9.0	27-14-23-30	ECLASS 9.1	27-21-03-01
ECLASS 10.0	27-14-23-30	ECLASS 11.0	27-14-23-30
ECLASS 12.0	27-14-23-30	ECLASS 13.0	27-14-23-30

## Approvals

Approvals	
ROHS	Conform

**ENERGY ANALYSER 550-24****Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

[www.weidmueller.com](http://www.weidmueller.com)**Technical data****Downloads**

Approval/Certificate/Document of Conformity

[Application notes – Declaration of Conformity](#)

Engineering Data

[CAD data – STEP](#)

Software

[Device description – GSD DATA](#)[Device description – MODBUS address list](#)[Win64 - ecoExplorer go](#)

User Documentation

[Quick Guide German/English](#)[Manual Energy Meter 550 German/English](#)[Application notes – Manual ECOEXPLORER GO English](#)

Catalogues

[Catalogues in PDF-format](#)

## ENERGY ANALYSER 550-24

**Weidmüller Interface GmbH & Co. KG**  
Klingenbergstraße 26  
D-32758 Detmold  
Germany

[www.weidmueller.com](http://www.weidmueller.com)

## Drawings

